

North High School Ventilation Summary

	Room	Ventilation Equipment Type	Minimum Fresh Air Required (CFM) ¹	Measured Fresh Air (CFM)	Room Ventilation Status at 50% Occupancy	Room Ventilation Status at 100% Occupancy	Nominal Occupancy Supported by Measured Fresh Air	Notes
	A009 office	AHU 3.6	25	262	●	●	36	
	A013 - Trainer	AHU 3.6	303	675	●	●	100	
	A013A - Trainer Office	AHU 3.6	9	87	●	●	11	
1st Floor	A101 - Field House	AHU 3.1 & 3.2	7742	8350	●	●	2498	
	A102 - Gymnasium	AHU 3.3 & 3.4	3950	4410	●	●	483	
	A103 - Classroom	AHU 3.5	513	545	●	●	33	
	A103A - Office	AHU 3.5	23	38	●	●	4	
	A105 - Office	AHU 3.5	97	151	●	●	13	
	A106 - Office	AHU 3.5	55	98	●	●	10	
	A107A - Office	AHU 3.5	15	37	●	●	2	
	A107B - Daycare	AHU 3.5	397	601	●	●	45	
	A107C - Classroom	AHU 3.5	264	390	●	●	22	
	A107D - Daycare	AHU 3.5	497	774	●	●	54	
	A107E - Break Rooms	AHU 3.5	44	64	●	●	8	
	A109 - Office	AHU 3.5	54	225	●	●	30	
	A109A - Conference Room	AHU 3.5	45	63	●	●	9	
	A109D - Sick Room	AHU 3.5	11	38	●	●	5	
	Boy Cot	AHU 3.5	29	117	●	●	4	
	Girl Cot	AHU 3.5	29	119	●	●	5	
	A111 - Classroom	AHU 3.5	789	1181	●	●	76	
	101 - Office	AHU 1.11	57	114	●	●	12	
	101A - Office	AHU 1.11	11	93	●	●	14	
	101B - Office	AHU 1.11	10	94	●	●	14	
	101C - Office	AHU 1.11	10	35	●	●	4	
	101D - Office	AHU 1.11	12	36	●	●	4	
	102 - Office	AHU 1.11	81	267	●	●	34	
	103 - Conference Room	AHU 1.11	233	225	●	●	29	Within margin of error of testing equipment.
	104 - Office	AHU 1.11	16	96	●	●	14	
	105 - Office	AHU 1.11	44	83	●	●	8	
	105A - Conference Room	AHU 1.11	78	122	●	●	17	
	105B - Office	AHU 1.11	20	45	●	●	5	
	108 - Office	AHU 1.11	15	34	●	●	4	
	109 - Break Room	AHU 1.11	43	83	●	●	11	
	110 - Office	AHU 1.11	104	133	●	●	10	
	110A - Office	AHU 1.11	13	43	●	●	5	
	110B - Office	AHU 1.11	10	52	●	●	7	
	110C - Office	AHU 1.11	11	52	●	●	7	
	110D - Office	AHU 1.11	12	65	●	●	9	
	111 - Main Office	AHU 1.11	146	280	●	●	28	
	111A - Office	AHU 1.11	24	64	●	●	7	
	111B - Office	AHU 1.11	15	99	●	●	14	
	111C - Office	AHU 1.11	17	38	●	●	4	
	111D - Office	AHU 1.11	21	36	●	●	3	
	111E - Office	AHU 1.11	16	38	●	●	4	
	112 - Office	AHU 1.11	16	40	●	●	5	
	112A - Conference Room	AHU 1.11	60	66	●	●	9	
	112B - Office	AHU 1.11	15	34	●	●	4	
	113 - Office	AHU 1.11	36	40	●	●	4	
	115 - Office	AHU 1.14	35	54	●	●	5	
	115A - Office	AHU 1.14	16	32	●	●	3	
	115B - Break Room	AHU 1.14	49	55	●	●	6	
	115C - Office	AHU 1.14	6	26	●	●	3	
	117 - Tiger's Loft Café	AHU 1.14 & MAU 1.2	1928	1955	●	●	153	
	119A - Office	AHU 1.14	21	31	●	●	3	
	119S - Office	AHU 1.14	14	30	●	●	3	
	121 - Office	AHU 1.23	115	570	●	●	78	
	124 - Photo Studio	AHU 1.23	172	330	●	●	33	
	124A - Photo Studio	AHU 1.23	60	250	●	●	33	
	124B - Photo Studio	AHU 1.23	131	350	●	●	41	
	125 - Office	AHU 1.23	15	59	●	●	8	
	125A - Office	AHU 1.23	18	101	●	●	14	
	125B - Office	AHU 1.23	21	56	●	●	7	
	126 - Office	AHU 1.23	21	60	●	●	7	
	127 - Art Classroom	AHU 1.23	582	583	●	●	25	
	129 - Art Classroom	AHU 1.23	548	557	●	●	24	
	131 - Art Classroom	AHU 1.23	618	698	●	●	32	
	131A - Kiln Room	AHU 1.23	0	290	●	●	NA	
	132 - Classroom	AHU 1.12	405	1399	●	●	104	
	133 - Print Shop	AHU 1.23	NA	2023	●	●	NA	
	133A - Computer Lab	AHU 1.23	366	568	●	●	36	
	133B - Office	AHU 1.23	42	284	●	●	41	
	134 - Office	AHU 1.12	24	32	●	●	2	
	135 - Office	AHU 1.23	41	319	●	●	46	
	135A - Office	AHU 1.23	16	67	●	●	9	
	135B - Conference Room	AHU 1.23	73	76	●	●	10	
	135C - Office	AHU 1.23	10	100	●	●	15	
	136 - Cafeteria	AHU 1.12	7729	15762	●	●	1457	Note 2
	136A - Con.	AHU 1.12	17	32	●	●	3	
	137 - Computer Lab	AHU 1.42	548	655	●	●	38	
	139 - Electronic Lab	AHU 1.42	513	889	●	●	52	
	139A - Office	AHU 1.42	18	120	●	●	17	
	140A - Office	AHU 1.32	24	58	●	●	7	
	140B - Office	AHU 1.32	9	28	●	●	4	
	141 - Computer Lab	AHU 1.42	412	431	●	●	24	
	142 - Office	AHU 1.32	22	58	●	●	7	
	142S - Break Room	AHU 1.33	67	68	●	●	7	
	143 - Office	AHU 1.42	9	27	●	●	3	
	144 - Receiving	AHU 1.42	101	131	●	●	24	
	145 - Maintenance/Repair	AHU 1.42	202	247	●	●	12	
	147 - Office	AHU 1.42	11	33	●	●	4	
	148 - Electronic Shop	AHU 1.42	856	1091	●	●	55	
	148A - Office	AHU 1.42	27	34	●	●	2	
	150 - Automotive Lab	AHU 1.42	331	410	●	●	20	
	150A - Office	AHU 1.42	33	45	●	●	4	
	150B - Automotive Shop	AHU 1.42	1246	1435	●	●	68	
	152 - Classroom	AHU 1.42	152	491	●	●	31	
	152A - Carpentry Shop	AHU 1.42	1982	2809	●	●	150	
	154 - Office	AHU 1.42	23	38	●	●	3	
	156 - Office	AHU 1.44	28	43	●	●	4	
	158 - Choral	AHU 1.44	784	927	●	●	64	
	158A - Classrooms	AHU 1.44	126	182	●	●	12	
	158B - Classrooms	AHU 1.44	108	158	●	●	10	
	158C - Classrooms	AHU 1.44	98	153	●	●	10	
	160 - Music Libraries	AHU 1.44	55	81	●	●	7	
	162 - Office	AHU 1.44	18	36	●	●	4	
	164 - Brand Orchestra	AHU 1.44	935	1348	●	●	95	
	170 - Office	AHU 2.4	27	34	●	●	2	
	171 - Office	AHU 2.4	60	89	●	●	8	
	172 - Theater	AHU 2.2	2085	4339	●	●	645	
	172A - Control Booth	AHU 2.4	94	106	●	●	14	
	173 - Little Theater	AHU 2.3	1210	2668	●	●	199	
	174 - Stage	AHU 2.1	1475	1560	●	●	107	
	175 - Rehearsal	AHU 2.4	420	452	●	●	31	
	177 - Control Booth	AHU 2.4	22	22	●	●	1	
	181 - Office	AHU 2.4	16	22	●	●	2	
	183 - Office	AHU 2.4	15	23	●	●	2	
	185 - Classroom	AHU 2.4	421	467	●	●	20	
	185A - Office	AHU 2.4	11	24	●	●	3	
2nd Floor	A203 - Dance/Wrestling	AHU 3.5	892	1335	●	●	48	
	A205 - Weight Room	AHU 3.5	663	1000	●	●	34	
	A206 - Conference Room	AHU 3.5	103	163	●	●	23	
	A207 - Classroom	AHU 3.5	434	479	●	●	29	
	A208 - Conference Room	AHU 3.5	96	153	●	●	21	
	A209 - Classroom	AHU 3.5	493	545	●	●	34	
	A210 - Office	AHU 3.5	22	41	●	●	4	
	A211 - Concession	AHU 3.5	19	28	●	●	3	
	A212 - Office	AHU 3.5	16	30	●	●	3	
	201 - Classroom	AHU 1.11	310	314	●	●	19	
	203 - Office	AHU 1.11	14	30	●	●	3	
	205 - Classroom	AHU 1.11	341	352	●	●	21	
	207 - Office	AHU 1.11	10	22	●	●	2	
	209 - Classroom	AHU 1.11	348	332	●	●	19	Within margin of error of testing equipment.
	210 - Classroom	AHU 1.11	347	395	●	●	24	
	211 - Office	AHU 1.11	21	35	●	●	3	
	212 - Office	AHU 1.11	16	27	●	●	3	
	213 - Office	AHU 1.11	26	42	●	●	4	
	214 - Classroom	AHU 1.11	345	381	●	●	23	
	215 - Classroom	AHU 1.11	532	572	●	●	33	
	216 - Office	AHU 1.11	61	358	●	●	51	
	216A - Office	AHU 1.11	10	28	●	●	3	
	216B - Conference Room	AHU 1.11	95	87	●	●	11	Within margin of error of testing equipment.
	216C - Office	AHU 1.11	16	35	●	●	4	
	217 - Classroom	AHU 1.11	511	495	●	●	29	Within margin of error of testing equipment.
	218 - Classroom	AHU 1.11	306	316	●	●	19	

	219 - Office	AHU 1.11	16	31	●	●	3	
	220 - Office	AHU 1.11	46	79	●	●	7	
	220A - Break Room	AHU 1.11	45	46	●	●	5	
	220B - Office	AHU 1.11	16	31	●	●	3	
	220C - Office	AHU 1.11	10	29	●	●	3	
	225 - Library	AHU 1.21	1577	1727	●	●	98	
	225A - Classroom	AHU 1.21	349	577	●	●	38	
	225B - Office	AHU 1.21	17	47	●	●	6	
	225C - Conference Room	AHU 1.21	78	96	●	●	13	
	225D Conference Room	AHU 1.21	76	96	●	●	13	
	225E Conference Room	AHU 1.21	88	108	●	●	15	
	225H - Office	AHU 1.21	21	25	●	●	2	
	225G - Office	AHU 1.21	10	25	●	●	3	
	225J - Break Room	AHU 1.21	84	97	●	●	11	
	225L - Classroom	AHU 1.21	518	566	●	●	34	
	240 - Office	AHU 1.31	189	268	●	●	38	
	241 - Office	AHU 1.31	26	59	●	●	7	
	241A - Office	AHU 1.31	20	35	●	●	3	
	241B - Office	AHU 1.31	10	20	●	●	2	
	241C - Office	AHU 1.31	10	20	●	●	2	
	241D - Office	AHU 1.31	10	20	●	●	3	
	241E - Office	AHU 1.31	8	20	●	●	2	
	241F - Office	AHU 1.31	12	39	●	●	5	
	241G - Office	AHU 1.31	11	24	●	●	3	
	241H - Office	AHU 1.31	11	24	●	●	3	
	241J - Office	AHU 1.31	11	47	●	●	6	
	241K - Office	AHU 1.31	9	20	●	●	2	
	241L - Office	AHU 1.31	11	20	●	●	2	
	241M - Office	AHU 1.31	12	27	●	●	3	
	241N - Conference Room	AHU 1.31	72	122	●	●	17	
	242 - Classroom	AHU 1.31	182	270	●	●	17	
	247 - Classroom	AHU 1.31	338	324	●	●	17	Within margin of error of testing equipment.
	249 - Classroom	AHU 1.31	342	313	●	●	16	Within margin of error of testing equipment.
	250A - Office	AHU 1.31	11	27	●	●	3	
	250B - Office	AHU 1.31	24	67	●	●	8	
	250C - Office	AHU 1.31	21	44	●	●	5	
	250D - Office	AHU 1.31	17	49	●	●	6	
	250E - Office	AHU 1.31	17	47	●	●	6	
	250F - Office	AHU 1.31	16	87	●	●	12	
	250G - Office	AHU 1.31	10	15	●	●	1	
	250H - Office	AHU 1.31	8	15	●	●	1	
	251 - Classroom	AHU 1.31	342	472	●	●	28	
	252 - Classroom	AHU 1.31	451	578	●	●	37	
	253 - Classroom	AHU 1.31	342	404	●	●	23	
	254 - Classroom	AHU 1.31	450	497	●	●	31	
	255 - Office	AHU 1.31	22	37	●	●	3	
	256 - Classroom	AHU 1.31	464	585	●	●	84	
	257 - Office	AHU 1.31	25	52	●	●	5	
	258 - Classroom	AHU 1.31	457	533	●	●	76	
	259 - Office	AHU 1.31	22	49	●	●	5	
	260 - Office	AHU 1.31	30	69	●	●	8	
	260B - Office	AHU 1.31	16	46	●	●	5	
	260C - Office	AHU 1.31	10	23	●	●	3	
	261 - Classroom	AHU 1.41	173	323	●	●	22	
	262 - Classroom	AHU 1.41	357	419	●	●	26	
	262A - Office	AHU 1.31	15	130	●	●	19	
	262B - Office	AHU 1.41	14	143	●	●	21	
	263 - Classroom	AHU 1.41	191	310	●	●	21	
	264 - Classroom	AHU 1.41	425	662	●	●	44	
	265 - Classroom	AHU 1.41	437	669	●	●	44	
	266 - Classroom	AHU 1.41	432	693	●	●	46	
	267 - Classroom	AHU 1.41	424	643	●	●	42	
	268 - Classroom	AHU 1.41	430	669	●	●	44	
	269 - Classroom	AHU 1.41	430	702	●	●	47	
	270 - Classroom	AHU 1.41	427	667	●	●	44	
	271 - Classroom	AHU 1.41	423	701	●	●	47	
	272 - Classroom	AHU 1.41	424	730	●	●	49	
	273 - Classroom	AHU 1.41	293	662	●	●	47	
	273A - Office	AHU 1.41	12	132	●	●	20	
	273B - Office	AHU 1.41	7	94	●	●	14	
	275 - Office	AHU 1.41	26	202	●	●	29	
	277 - Conference Room	AHU 1.41	186	284	●	●	40	
	277A - Office	AHU 1.41	16	135	●	●	20	
	277B - Break Room	AHU 1.41	46	198	●	●	29	
3rd Floor	301 - Office	AHU 1.16	21	33	●	●	3	
	303 - Break Room	AHU 1.16	60	62	●	●	7	
	305 - Classrooms	AHU 1.16	294	354	●	●	22	
	307 - Office	AHU 1.16	16	26	●	●	2	
	309 - Classroom	AHU 1.16	304	361	●	●	52	
	310 - Classroom	AHU 1.16	348	416	●	●	58	
	311 - Classroom	AHU 1.16	430	512	●	●	73	
	312 - Classroom	AHU 1.16	350	400	●	●	55	
	313 - Classroom	AHU 1.16	425	505	●	●	72	
	313A - Office	AHU 1.16	13	44	●	●	6	
	314 - Classroom	AHU 1.16	349	416	●	●	58	
	315 - Classroom	AHU 1.16	425	536	●	●	77	
	315A - Office	AHU 1.16	21	33	●	●	3	
	316 - Classroom	AHU 1.16	353	416	●	●	57	
	318 - Classroom	AHU 1.16	237	218	●	●	30	Within margin of error of testing equipment.
	319 - Classroom	AHU 1.16	501	613	●	●	88	
	320A - Office	AHU 1.21	11	24	●	●	3	
	320B - Office	AHU 1.21	10	21	●	●	2	
	320C - Office	AHU 1.21	20	34	●	●	3	
	321 - Break Room	AHU 1.21	160	176	●	●	20	
	321A - Office	AHU 1.21	10	84	●	●	12	
	321B - Office	AHU 1.21	12	17	●	●	1	
	321C - Office	AHU 1.21	12	17	●	●	1	
	321D - Office	AHU 1.21	12	18	●	●	2	
	321E - Office	AHU 1.21	12	18	●	●	2	
	321F - Office	AHU 1.21	11	18	●	●	2	
	321G - Office	AHU 1.21	11	17	●	●	2	
	321H - Office	AHU 1.21	11	17	●	●	2	
	322 - Classroom	AHU 1.21	479	484	●	●	29	
	323 - Classroom	AHU 1.21	455	484	●	●	29	
	324 - Classroom	AHU 1.21	479	502	●	●	30	
	325 - Classroom	AHU 1.21	480	494	●	●	30	
	326 - Classroom	AHU 1.21	479	494	●	●	30	
	327 - Classroom	AHU 1.21	455	509	●	●	31	
	328 - Classroom	AHU 1.21	479	503	●	●	30	
	329 - Classroom	AHU 1.21	455	501	●	●	31	
	330 - Classroom	AHU 1.21	499	719	●	●	47	
	331 - Classroom	AHU 1.21	314	314	●	●	19	
	333 - Office	AHU 1.35	23	40	●	●	4	
	335 - Office	AHU 1.35	39	83	●	●	9	
	337 - Office	AHU 1.35	23	35	●	●	3	
	339 - Office	AHU 1.35	20	28	●	●	2	
	341 - Office	AHU 1.35	17	24	●	●	2	
	343 - Classroom	AHU 1.35	344	424	●	●	26	
	343A - Office	AHU 1.35	5	20	●	●	3	
	344 - Classroom	AHU 1.35	348	396	●	●	24	
	344A - Office	AHU 1.35	6	32	●	●	5	
	345 - Office	AHU 1.35	44	71	●	●	6	
	346 - Office	AHU 1.35	21	37	●	●	3	
	347 - Office	AHU 1.35	16	25	●	●	2	
	348 - Office	AHU 1.35	16	32	●	●	3	
	349 - Classroom	AHU 1.35	344	441	●	●	28	
	349A - Office	AHU 1.35	5	20	●	●	3	
	350 - Classroom	AHU 1.35	430	562	●	●	36	
	351 - Classroom	AHU 1.35	344	447	●	●	26	
	352 - Classroom	AHU 1.35	430	553	●	●	35	
	353 - Classroom	AHU 1.35	344	447	●	●	26	
	354 - Classroom	AHU 1.35	430	560	●	●	35	
	355 - Classroom	AHU 1.35	344	439	●	●	26	
	356 - Classroom	AHU 1.35	430	595	●	●	38	
	358 - Break Room	AHU 1.35	136	179	●	●	22	
	358A - Office	AHU 1.35	9	18	●	●	2	
	358B - Office	AHU 1.35	10	18	●	●	2	
	358C - Office	AHU 1.35	10	29	●	●	3	
	358D - Office	AHU 1.35	11	29	●	●	3	
	358E - Office	AHU 1.35	11	28	●	●	3	
	358F - Office	AHU 1.35	10	28	●	●	3	
	358G - Office	AHU 1.35	10	17	●	●	2	
	358H - Office	AHU 1.35	9	17	●	●	2	
	358I - Office	AHU 1.35	10	19	●	●	2	
	358J - Office	AHU 1.35	10	19	●	●	2	
	359 - Break Room	AHU 1.35	134	168	●	●	20	
	359A - Conference Room	AHU 1.35	79	119	●	●	19	
	359B - Office	AHU 1.35	17	29	●	●	3	
	359C - Office	AHU 1.35	17	29	●	●	3	
	361 - Classroom	AHU 1.41	368	609	●	●	41	
	363 - Classroom	AHU 1.41	428	666	●	●	44	

	364 - Classroom	AHU 1.41	331	496	●	●	33	
	364A - Office	AHU 1.41	16	29	●	●	3	
	365 - Classroom	AHU 1.41	428	650	●	●	43	
	366 - Classroom	AHU 1.41	328	481	●	●	32	
	366A - Office	AHU 1.41	14	30	●	●	3	
	367 - Classroom	AHU 1.41	428	655	●	●	43	
	368 - Classroom	AHU 1.41	431	662	●	●	43	
	369 - Classroom	AHU 1.41	428	665	●	●	44	
	370 - Classroom	AHU 1.41	421	671	●	●	45	
	371 - Classroom	AHU 1.41	428	648	●	●	43	
	372 - Classroom	AHU 1.41	424	686	●	●	46	
	373 - Office	AHU 1.41	13	31	●	●	3	
	373A - Conference Room	AHU 1.41	68	122	●	●	17	
	373B - Office	AHU 1.41	16	46	●	●	5	
	375 - Office	AHU 1.41	24	46	●	●	5	
	377 - Office	AHU 1.41	20	44	●	●	5	
4th Floor	401 - Office	AHU 1.13	22	72	●	●	3	
	403 - Office	AHU 1.13	23	65	●	●	3	
	405 - Office	AHU 1.13	23	105	●	●	6	
	409 - Classroom	AHU 1.13	582	660	●	●	41	
	410 - Classroom	AHU 1.13	705	798	●	●	49	
	411 - Classroom	AHU 1.13	699	720	●	●	43	
	412 - Classroom	AHU 1.13	162	442	●	●	21	
	413 - Classroom	AHU 1.13	154	392	●	●	28	
	414 - Classroom	AHU 1.13	705	920	●	●	59	
	415 - Classroom	AHU 1.13	699	820	●	●	62	
	416 - Classroom	AHU 1.13	303	360	●	●	23	
	417 - Greenhouse	AHU 1.13	62	270	●	●	17	
	418 - Classroom	AHU 1.13	43	285	●	●	41	
	419 - Music Classroom	AHU 1.13	357	530	●	●	38	
	420A - Office	AHU 1.24	12	158	●	●	24	
	420B - Office	AHU 1.24	10	155	●	●	24	
	420C - Office	AHU 1.24	21	200	●	●	30	
	421 - Office	AHU 1.24	74	740	●	●	110	
	421A - Office	AHU 1.24	10	49	●	●	7	
	421B - Office	AHU 1.24	12	21	●	●	2	
	421C - Office	AHU 1.24	12	49	●	●	7	
	421D - Office	AHU 1.24	12	49	●	●	7	
	421E - Office	AHU 1.24	12	54	●	●	7	
	421F - Office	AHU 1.24	10	50	●	●	7	
	421G - Office	AHU 1.24	10	49	●	●	7	
	421H - Office	AHU 1.24	10	49	●	●	7	
	421I - Office	AHU 1.24	10	49	●	●	7	
	422 - Classroom	AHU 1.24	244	436	●	●	30	
	423 - Classroom	AHU 1.24	269	481	●	●	33	
	424 - Classroom	AHU 1.24	702	2310	●	●	170	
	425 - Classroom	AHU 1.24	705	2845	●	●	213	
	426 - Classroom	AHU 1.24	190	450	●	●	32	
	427 - Classroom	AHU 1.24	160	450	●	●	33	
	428 - Classroom	AHU 1.24	691	2480	●	●	184	
	429 - Classroom	AHU 1.24	697	2100	●	●	154	
	430 - Computer Lab	AHU 1.24	390	1800	●	●	134	
	433 - Office	AHU 1.24	31	356	●	●	53	
	435 - Classroom	AHU 1.33	703	725	●	●	44	
	441 - Classroom	AHU 1.33	153	170	●	●	10	
	443 - Classroom	AHU 1.33	705	700	●	●	42	Within margin of error of testing equipment.
	444 - Classroom	AHU 1.33	781	750	●	●	44	Within margin of error of testing equipment.
	449 - Classroom	AHU 1.33	677	705	●	●	43	
	450 - Classroom	AHU 1.33	145	164	●	●	10	
	451 - Classroom	AHU 1.33	149	160	●	●	10	
	452 - Classroom	AHU 1.33	766	770	●	●	46	
	453 - Classroom	AHU 1.33	689	770	●	●	48	
	454 - Classroom	AHU 1.33	780	900	●	●	56	
	455 - Classroom	AHU 1.33	248	300	●	●	19	
	456 - Classroom	AHU 1.33	150	150	●	●	9	
	457 - Office	AHU 1.43	23	59	●	●	7	
	458 - Classroom	AHU 1.33	806	810	●	●	48	
	459 - Office	AHU 1.43	25	40	●	●	4	
	460 - Break Room	AHU 1.43	185	245	●	●	30	
	460A - Office	AHU 1.43	10	28	●	●	3	
	460B - Office	AHU 1.43	10	28	●	●	3	
	460C - Office	AHU 1.43	10	40	●	●	5	
	460D - Office	AHU 1.43	10	37	●	●	5	
	460E - Office	AHU 1.43	10	30	●	●	4	
	460F - Office	AHU 1.43	10	30	●	●	4	
	460G - Conference Room	AHU 1.43	85	150	●	●	21	
	460H - Office	AHU 1.43	19	64	●	●	8	
	460I - Office	AHU 1.43	19	106	●	●	15	
	461 - Classroom	AHU 1.43	203	262	●	●	15	
	463 - Classroom	AHU 1.43	428	599	●	●	39	
	464 - Classroom	AHU 1.43	432	593	●	●	38	
	465 - Classroom	AHU 1.43	428	606	●	●	39	
	466 - Classroom	AHU 1.43	432	609	●	●	39	
	467 - Classroom	AHU 1.43	428	618	●	●	40	
	468 - Classroom	AHU 1.43	432	588	●	●	38	
	469 - Classroom	AHU 1.43	428	615	●	●	40	
	470 - Classroom	AHU 1.43	432	624	●	●	40	
	471 - Classroom	AHU 1.43	428	621	●	●	40	
	472 - Classroom	AHU 1.43	432	606	●	●	39	
	473 - Classroom	AHU 1.43	530	922	●	●	61	

1. Air flow calculated using ASHRAE 62.1 and the International Mechanical Code default values for fully occupied spaces.

2. Calculated at max occupancy of 600 as specified by city of Newton.